LGAI Technological Center, S.A. (APPLUS)
Campus UAB - Ronda de la Font del Carme s/n
08193 Bellaterra (Barcelona)
T +34 93 567 20 00
www.applus.com





CERTIFICATE



No.

0370-CPR-3782

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

POWER, CONTROL AND COMMUNICATION CABLES. CABLES FOR GENERAL APPLICATIONS IN CONSTRUCTION WORKS SUBJECT TO REACTION TO FIRE REQUIREMENTS.

FAMILY: LiHH CLASSIFICATION: Cca-s1, d0, a1

Place on the market under the name of:

TRİO KABLO IMALATI SANAYI VE TIC. LTD. ŞTI.

PERPA TİCARET MERKEZİ B-BLOK KAT:2 No:15 OKMEYDANI / İSTANBUL / TURKEY

And produced in the manufacturing plant:

OSMANGAZİ MAHALLESİ 2644 SOKAK Nº: 3/1 34522 KIRAÇ / ESENYURT / İSTANBUL / TURKEY

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 50575:2014, EN 50575:2014/A1:2016

under system 1+ are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 12th November 2019 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

The monitoring assessment will be done before October 2020

Bellaterra, 11th October 2019

Applus Center, S.A.

Xavier Ruiz Peña

Managing Director, Product Conformity B.U.

This document is not valid without its technical annex; whose number coincides with the certificate number.



LGAI Technological Center, S.A. (APPLUS)
Campus UAB s/n – Ronda de la Font del Carme, s/n
E - 08193 Bellaterra (Barcelona)
T +34 93 567 20 00
www.appluslaboratories.com



Technical Annex Ed. 1 12/11/2019

0370-CPR-3782

DESIGNATION	LiHH 300/500
REACTION TO FIRE CLASS	C _{ca} -s1, d0, a1

CROSS SECTIONAL RANGE	RATED VOLTAGE
Conductor of 0.22 mm² (number of conductors: 8, 10, 12, 14, 16, 18, 19, 20, 24, 25) Conductor of 0.5 mm² (number of conductors: 4, 5, 6, 7, 8, 10, 12, 14, 16, 18, 19, 20, 24, 25) Conductor of 0.75 mm² (number of conductors: 2, 3, 4, 5, 6, 7, 8, 10, 12, 14, 16, 18, 19, 20, 24, 25) Conductor of 1 mm² (number of conductors: 2, 3, 4, 5, 6, 7, 8, 10, 12, 14, 16, 18, 19, 20, 24, 25) Conductor of 1.5 mm² (number of conductors: 2, 3, 4, 5, 6, 7, 8, 10, 12, 14, 16, 18, 19, 20, 24, 25) Conductor of 2.5 mm² (number of conductors: 2, 3, 4, 5, 6, 7, 8, 10, 12, 14, 16, 18, 19, 20, 24, 25) Conductor of 4 mm² (number of conductors: 2, 3, 4, 5, 6, 7) Conductor of 6 mm² (number of conductors: 2, 3, 4, 5, 6, 7) Conductor of 10 mm² (number of conductors: 2, 3, 4, 5, 6, 7) Conductor of 16 mm² (number of conductors: 2, 3, 4, 5, 6, 7) Conductor of 16 mm² (number of conductors: 2, 3, 4, 5, 6, 7)	300/500V